

**Acme Township Development  
Storm Water Run-Off**

April 10, 2015

**Observations:**

I made an onsite visit today to the new development in Acme Township. Talked to Horizon Environmental he checked turbidity levels this morning at 8:00AM 18 on the downstream and 11 on the upstream side. While on site witnessed Horizon Environmental performed another turbidity test again at 10:45AM 11 on the downstream side and 7 on the upstream side. The site looked good after all the rain fall.

**Corrective Actions:**

- No corrective actions are needed at this time.

Overall the contractor still needs to work with the Horizon Environmental to get the site stabilized. The contractor does have some good measures in place to keep storm water from leaving the site but the biggest thing is to get the site stabilized.

Submitted By,

Bernie Jacobson DEQ Number 10523