

**Acme Township Development
Storm Water Run-Off**

April 9, 2015

Observations:

I made an onsite visit today to the new development in Acme Township. Miller Pipeline was along M-72 installing gas main, they were installing mulch blanket rite behind to prevent any erosion problems. Silt fence was in good shape nothing was torn down. Straw bales that contractor installed this past winter was in good shape. Overall the site was in good shape.

Corrective Actions:

- No corrective actions are needed at this time.

Overall the contractor still needs to work with the Horizon Environmental to get the site stabilized. The contractor does have some good measures in place to keep storm water from leaving the site but the biggest thing is to get the site stabilized.

Submitted By,

Bernie Jacobson DEQ Number 10523