

**Acme Township Development
Storm Water Run-Off**

May 26, 2015

Observations:

I made an onsite visit today to the new development in Acme Township. Inspected the site for any soil erosion problems. The amount of rainfall for 5/24/2015 was 1.33" according to the onsite rain gauge. The Villages Grand Traverse site was in really good shape no appearance of runoff. The project that was being done on M-72 had some serious issues. The rainfall over ran the silt fence that DJ McQuestions (M-72 contractor) installed and ran onto the property of the Villages of Grand Traverse and some sediment to be sitting in the swale on the south side of M-72.

Corrective Actions:

- No corrective actions are needed at this time.

Overall the contractor still needs to work with the Horizon Environmental to get the site stabilized. The contractor does have some good measures in place to keep storm water from leaving the site but the biggest thing is to get the site stabilized.

Submitted By,

Bernie Jacobson DEQ Number 10523