

Acme Township Development

Storm Water Run-Off

October 21, 2014

Made an on site visit today to the development in Acme Township. Inspected the site for soil erosion. Overall the site has faced a lot of rain fall for the month of October. They had good Best Management Practices in place to control the runoff on site. Seen a few things that could be addressed to help control runoff of sediment from the site.

- Contractor needs to police a silt fence on the site to prevent further run-off from the site.
- The site has good seeding and mulching on the site. With this time of year grass seed will not germinate. Contractor needs to install mulch and mulch blanket on top of seed to prevent run-off of the seed in the spring time.
- Overall the site looked good and contractor is doing its best to secure the sediment from leaving the site.
- Looked at the NPDES logs that were put together by GFA.

Overall the contractor still needs to work with the Gourdie Fraser to get the site stabilized. The contractor does have some good measures in place to keep storm water from leaving the site but the biggest thing is to get the site stabilized. Contractor was completed with the Meijer parking lot and getting that area secured.

Submitted By

Bernie Jacobson DEQ Number 10523