

## Acme Township Development

### Storm Water Run-Off

October 23, 2014

Made an on site visit today to the development in Acme Township. Inspected the site for soil erosion and for problem areas where sediment can leave the site. Overall the site has faced a lot of rain fall for the month of October. They had good Best Management Practices in place to control the runoff on site. Seen a few things that could be addressed to help control runoff of sediment from the site.

- Contractor needs to police a silt fence on the site to prevent further run-off from the site.
- Contractor has been installing curb and gutter along the roadways.
- Contractor has been installing gravel at the main entrance from M72.
- Need to install stone at the entrances to the site so any collection of dirt on tires of vehicles cannot leave the site.

Overall the contractor still needs to work with the Gourdie Fraser to get the site stabilized. The contractor does have some good measures in place to keep storm water from leaving the site but the biggest thing is to get the site stabilized. Contractor was completed with the Meijer parking lot and getting that area secured.

Submitted By

Bernie Jacobson DEQ Number 10523